

Ref.Spec.17

SPECIFICATIONS

“Nayara LDO”

| Sr. No. | Parameters | Unit | Test Method | Limit | Test Results |
|---------|-------------------------------|-------------------|-------------------|------------|--------------|
| 1. | Appearance | - | Visual | To Report | Dark Brown |
| 2. | Acidity, inorganic | - | IS 1448 [P:2] | NIL | NIL |
| 3. | Ash | % mass | IS 1448 [P:4] | 0.02 Max | <0.01 |
| 4. | Carbon Residue | % mass | IS 1448 [P:8] | 1.5 Max | 0.14 |
| 5. | Pour Point | °C | IS 1448 [P:10] | Note 1 | -21 |
| 6. | Copper Strip corrosion | - | IS 1448 [P:15] | Note 2 | 1b |
| 7. | Flash Point | °C | IS 1448 [P:21] | 66 Min | 75 |
| 8. | Kinematic Viscosity, at 40° C | cSt | IS 1448 [P:25] | 2.5 – 15.0 | 3.956 |
| 9. | Sediment | % mass | IS 1448 [P:30] | 0.1 Max | 0.02 |
| 10. | Density at 15° C | Kg/m ³ | IS 1448 [P:16] | To Report | 871.9 |
| 11. | Water Content | Vol % | IS 1448 [P:40] | 0.25 Max | <0.05 |
| 12. | Total Sulphur | % mass | ASTM D 4294 | 1.5 Max | 0.42 |

- The photocopies of following licenses are required:
GST Certificate.
- The price is subject to change. Pl confirm before payment.
- Specification as provided by the manufacturer
- For sample, price, delivery, and availability Pl contact Mr. Varun – 9004365926
Mr. Nilesh – 9920494214, Office -91 22 28077450, 91-22 28017099